



CERTIFICATE OF TEST

Date of issue:	11 th January 2008	Project number:	07/0968
Applicant:	Bifold Fluidpower Ltd	Reference:	1688
Address:	Greenside Way, Middleton, Manchester, M24 1SW.	Test record sheet:	TR/07/0968/1

Description of Test Sample

A Type FP Solenoid enclosure used on certificates BAS02ATEX2048, Baseefa02ATEX0124X and Baseefa03ATEX0509X.

Drawings

See certificates listed above.

Specification

The manufacturer requested Ingress Protection (IP) tests to be carried out in accordance with EN 60529.

Result

Type FP Solenoid Enclosures made in accordance with the drawing specified on the certificates above meet the requirements for an IP rating of IP67.

Comments

Suitable cable entry devices must be used which maintain the IP rating of the enclosure.

Test carried out by: **Miles Needham**

Checked and approved by: **David Brearley**

This certificate is granted subject to the general terms and conditions of Baseefa (2001) Ltd. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.



Baseefa
Rockhead Business Park, Staden Lane,
Buxton, Derbyshire SK17 9RZ
Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601
e-mail info@baseefa.com web site www.baseefa.com
Baseefa is a trading name of Baseefa (2001) Ltd
Registered in England No. 4305578 at the above address


R S SINCLAIR
DIRECTOR
On behalf of
Baseefa (2001) Ltd.